



Fire Doors on Campus

Fire doors are installed in all buildings to reduce the spread of fire and smoke. Fire doors have been tested to have a “fire-resistance rating”. This rating is posted on door jams and annotates the amount of time the door is able hold back fire and smoke.

Propping open fire doors is **PROHIBITED**.

The Saskatoon Fire Inspector can issue fines for improperly propping doors open. The fine (\$250.00 - first offence) will be issued to the person responsible for the building.

To aid in fire prevention on campus:

1. Do not prop open a door with doorstop, wooden wedge or other obstacle. Doors can be held open magnetically, if their design allows.
2. Do not run a carpet or any other material beneath a fire door.
3. Do not remove or obscure a fire door’s certification markings (displayed both on the door leaves and the fire door frames).
4. Do not alter or decorate fire doors. Attaching fixtures or combustible materials to a fire door is prohibited.

